



**PHIFER**  
INCORPORATED

25 April 2022

Re: SheerWeave Infinity 2, 1% Basket Weave

**PHIFER INCORPORATED** (Tuscaloosa, Alabama) certifies that the material referenced above complies with the standards listed below:

1. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. (Tested in accordance to ASTM E84-21a, Surface Burning Characteristics of Building Materials.)  
FLAME SPREAD INDEX = 5 SMOKE DEVELOPED VALUE =250
2. International Building Code (IBC), Section 803.1.1.1, (Tested in accordance to ASTM E84), Class "A" rating.
3. NFPA 701-2019, Standard Methods of Fire Test for Propagation of Textiles and Films 2015 Edition, (Test 1, Small Scale).
4. CAN/ULC-S109-14 Standard for Flame Tests of Flame-Resistant fabrics & Films, Small Flame Test.
5. CAN/ULC-S109-14 Standard for Flame Tests of Flame-Resistant Fabrics & Films, Large Flame Test, Single Sheet Specimen.

If you have any questions or need further information, please contact me at 1-800-633-5955 Ext. 3075.

Sincerely,

**PHIFER INCORPORATED**

Keith Euerle

Director of Specialty Textiles Testing and Analysis

\*Testing was performed by a 3<sup>rd</sup> party certified laboratory on samples representing products listed.